



# Instruction REG 15 - 65, REG-SS 15 - 40



1



ENGLISH

# Installation

#### Refrigerants

Applicable to all common non-flammable refrigerants, including R717 and noncorrosive gases/liquids dependent on sealing material compatability. Flammable hydrocarbons are not recommended. The valve is only recommended for use in closed circuits. For further information please contact Danfoss.

#### Temperature range

REG: -50/+150°C (-58/+302°F) REG-SS: -60/+150°C (-76/+302°F)

#### **Pressure range**

The valves are designed for a max. working pressure of 40 bar g (580 psi g).

#### Installation

The valve must be installed with the spindle vertically upwards or in horizontal position (fig. 1). Valves should be opened by hand according to the guidelines in the datasheet. The valve is designed to withstand a high internal pressure. However, the piping system should be designed to avoid liquid traps and reduce the risk of hydraulic pressure caused by thermal expansion. It must be ensured that the valve is protected from pressure transients like "liquid hammer" in the system.

#### **Recommended flow direction**

Direct the flow towards the cone as indicated by the arrow placed on the valve housing (fig. 2). The force used to open and close the valve must not exceed the force of an ordinary handwheel.

# Welding

The bonnet should be removed before welding (fig. 3) to prevent damage to the O-rings in the packing gland and between the valve body and bonnet, as well as the teflon gasket in the valve seat. Only materials and welding methods, compatible with the valve housing material, must be welded to the valve housing. The valve should be cleaned internally to remove welding debris on completion of welding and before the valve is reassembled.

Avoid welding debris and dirt in the threads of the housing and the bonnet.

Removing the bonnet can be omitted provided that:

The temperature in the area between the valve body and bonnet during welding does not exceed +150°C/+302°F. This temperature depends on the welding method as well as on any cooling of the valve body during the welding itself. (Cooling can be ensured by, for example, wrapping a wet cloth around the valve body.) Make sure that no dirt, welding debris etc. get into the valve during the welding procedure.

Be careful not to damage the teflon cone ring.

The valve housing must be free from stresses (external loads) after installation.

REG valves must not be mounted in systems where the outlet side of the valve is open to atmosphere. The outlet side of the valve must always be connected to the system or properly capped off, for example with a welded-on end plate.

#### Assembly

Remove welding debris and any dirt from pipes and valve body before assembly. Check that the cone has been fully screwed back towards the bonnet before it is replaced in the valve body (fig. 4).

#### Tightening

Tighten the bonnet with a torque wrench, to the values indicated in the table (fig. 4).

#### **Colours and identification**

The REG valves are painted with a red oxide primer in the factory. Stainless steel valves are not painted. Precise identification of the valve is made via the ID ring at the top of the bonnet, as well as by the stamping on the valve body. The external surface of the valve housing must be prevented against corrosion with a suitable protective coating after installation and assembly.

Protection of the ID ring when repainting the valve is recommended.

#### Maintenance

#### Packing gland

When performing service and maintenance, replace the complete packing gland only, which is available as a spare part. As a general rule, the packing gland must not be removed if there is internal pressure in the valve. However, if the following precautionary measures are taken, the packing gland can be removed with the valve still under pressure:

#### Backseating (fig. 5)

To backseat the valve, turn the spindle counter-clockwise until the valve is fully open.

#### Pressure equalization (fig. 6)

In some cases, pressure forms behind the packing gland. Hence a handwheel or similar should be fastened on top of the spindle while the pressure is equalized. The pressure can be equalized by slowly screwing out the gland.

**Removal of packing gland (fig. 7)** Cap and packing gland can now be removed.

# Dismantling the valve

Do not remove the bonnet while the valve is still under pressure.

- Check that the O-ring (fig. 9, pos. A) has not been damaged.
- Check that the spindle is free of scratches and impact marks.
- If the teflon cone ring has been damaged, the whole cone assembly must be replaced.

# Replacement of the cone (fig. 10)

Unscrew the cone se	crew (pos. B) with an
Allen key.	
REG 15-40	2.0 mm A/F
REG 50-65	2.5 mm A/F

(An Allen key is included in the Danfoss Industrial Refrigeration gasket set). Remove the balls (pos. C).

Number of balls in fig. 10, pos. C: REG with cone no. 4-5-6-7 ...... 10 pcs. REG with cone no. 8-9-10-11-12 ..... 14 pcs.

The cone can then be removed. Place the new cone on the spindle and replace the balls. Refit the cone screw in again using Loctite No. 648. to ensure that the screw is properly fastened.

#### Assembly

Remove any dirt from the body before the valve is assembled. Check that the cone has been screwed back towards the bonnet before it is replaced in the valve body (fig. 4).

#### Tightening

Tighten the bonnet with a torque wrench, to the values indicated in the table (fig. 4). Tighten the packing gland with a torque wrench, to the values indicated in the table (fig. 8).

Use only original Danfoss parts, including packing glands, O-rings and gaskets for replacement. Materials of new parts are certified for the relevant refrigerant.

In cases of doubt, please contact Danfoss.

Danfoss accepts no responsibility for errors and omissions. Danfoss Industrial Refrigeration reserves the right to make changes to products and specifications without prior notice.

<u>Danfoss</u>

# Name and Address of Manufacturer within the European Community

Danfoss Industrial Refrigeration A/S Stormosevej 10 PO Box 60 DK-8361 Hasselager Denmark

#### Declaration

We hereby declare that below-mentioned equipment are Classified for Fluid Group I (all refrigerants (toxic, non-toxic, flammable and non-flammable)), and that all are covered by Article 3, paragraph 3.

For further details / restrictions - see Installation Instruction

#### **Description of Pressure Equipment**

Refrigerant regulating valve, with straight or angled bonnet arrangement Type **REG**, **REG-SS** 

Nominal bore  $DN \leq 25 \text{ mm.} (1 \text{ in.})$ 

# References of other Technical Standards and Specifications used

DIN 3158

prEN 12284 AD-Merkblätter

References of other Technical Standards and Specifications usedprEN 12284DIN 3158AD-MerkblätterDIN 3158

#### Authorised Person for the Manufacturer within the European Community

Name:	Morten Steen Hansen	Title:	Production Manager
Signature:	Martin Steen Hansen	Date:	07/01/2003

Danfoss

#### Name and Address of Manufacturer within the European Community

Danfoss Industrial Refrigeration A/S Stormosevej 10 PO Box 60 DK-8361 Hasselager Denmark

# **Description of Pressure Equipment**

Refrigerant stop valve, with straight or angled bonnet arrangement

# Type REG

Nominal bore	<b>DN27-65 mm.</b> (1 <sup>1</sup> / <sub>8</sub> - 2 <sup>1</sup> / <sub>2</sub> in.)	
Classified for	<b>Fluid Group I</b> (all refrigerants (toxic, nontoxic, flammable and nonflammable)). For further details / restrictions - see Installation Instruction.	
Temperature range and maximum allowable working pressure	REG	PS40 bar (580 psi) at –50°C/+150°C (-58°F/+302°F)
	REG-SS	PS40 bar (580 psi) at –60°C/+150°C (-76°F/+302°F)

# **Conformity and Assessment Procedure Followed**

Category	II
Module	D1
Certificate ID	D1: 07 202 0511 Z 0009/1/H-0002

# Name and Address of the Notified Body which carried out the Inspection

TÜV-Nord e.V. Grosse Bahnstrasse 31 22525 Hamburg, Germany

**(**0045)

# Name and Address of the Notified Body monitoring the Manufacturer's Quality Assurance System TÜV-Nord e.V.

Grosse Bahnstrasse 31 22525 Hamburg, Germany

#### References of Harmonised Standards used EN 10028-3 EN 10222-4

References of other Technical Standards and Specifications usedprEN 12284DIN 3158AD-MerkblätterDIN 3158

Authorised Person for the Manufacturer within the European Community

١.

Name:

Morten Steen Hansen

١ø

1

Title: Production Manager

Signature:

vtin	Steen	Mangen

Date: 10/03/2003

148B9717 - rev. 2